



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/17/09

Code 50.11.5,2-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- Dashed-line-through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title		Edition
Indiana Residential Code		2009
Section number and title		Page
R703.8 Flashing		370-371
Proponent	Title	
Calvin Bolt Inspections and Testing	Owner	
Address		Phone
1310 Oriole Drive Warsaw, IN 46580		574-269-3507
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input checked="" type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>In Section 703.8, delete item 1 and substitute to read as follows: 1. Corrosion-resistive flashing shall be provided at the sill, jambs, and top of all windows and door openings, applied shingle fashion in such a manner as to be leakproof. Tops of trim over these opening will also be head flashed in a manner as to direct water over the exterior wall cladding and not behind such trim. This head flashing may be omitted when protected by a soffit, porch, or similar overhang.</p>		
REASON		
<p>This language is from the 2005 Indiana Residential Code.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		